

FIRE AND RESCUE STATION, TANUR
DATE : 17/02/2026
Phone : 0494 2966101
Email.id: stationofficerfrstnr@gmail.com

STATION OFFICER
FIRE AND RESCUE STATION
TANUR

THE MANAGER
LITTLE HEART ENGLISH SCHOOL
TIRURANGADI
MALAPPURAM-676303

Sub : Fire and rescue station, Tanur- Fire NOC regarding
Ref (1) : Your Application dated 17/02/2026
(2) : Govt. Circular No:75/RD 3/2019 dtd 29/03/2019

As per Rule 53,54,56,57 of the KMBR Amendment act it is not necessary to obtain Fire NOC to a Building up to a built up area of 1000 M² and 15 M height under the group of A1,A2,BC,EF,G1,G2 and H. The educational building at R.S. No 369/9, Ward No 12, Neduva village, Parappanangadi Municipality owned by you is within the above limit, hence the Fire NOC is not required.



Yours faithfully

സ്റ്റേഷൻ ഓഫീസർ
അഗ്നിരക്ഷാ നിക്ഷേപം
താ.നമ്പർ - 676 302
ഫോൺ: 0494 2966101

[Handwritten Signature]
17/2/2026

STATION OFFICER
FIRE AND RESCUE STATION
TANUR